

Errata for 2010 *Guidelines for Design and Construction of Health Care Facilities**

Content Corrections

PAGE	SECTION	ERROR	CORRECTION
xxv	3rd bullet under Part 2: Hospitals	Windows in patient rooms to be at least 10 percent . . . (corrected to match <i>Guidelines</i> text found in Section 2.1-7.2.2.5 (p. 59))	Windows in patient rooms to be at least <u>8</u> percent . . .
xxix	Glossary	Adjacent: Contiguous, adjoining, or abutting. Implies physical attachment.	Adjacent: <u>Not distant, nearby (close at hand).</u>
xxxiii	Acronyms	VAV—variable air ventilation	VAV—variable air <u>volume</u>
11	1.1-5.5	ASTM E2638-08 was erroneously included in the list of referenced codes and standards. This standard appeared too late for its content to be considered in developing <i>Guidelines</i> Table 1.2-4 for public review.	This ASTM standard will be considered in reviewing the text in <i>Guidelines</i> Table 1.2-4 (Design Criteria for Speech Privacy for Enclosed Rooms and Open-Plan Spaces) during the 2014 <i>Guidelines</i> revision cycle.
50	2.1-2.4.3.5 (3)(b)	Door openings shall be a minimum . . .	Door openings shall <u>have</u> a minimum . . .
66	2.1-8.2.2.6	(2) Local exhaust shall be provided.	(2) Local exhaust shall be provided <u>for sputum collection procedures.</u>
67	2.1-8.2.4.1	Return air systems. For patient care areas, return air shall be via ducted systems.	Return air systems. <u>See Section 6.7.1 (Air Distribution Systems—General) in Part 6: ANSI/ASHRAE/ASHE 170: Ventilation of Health Care Facilities for ducted return requirements.</u>
83	Table 2.1-1	This table was intended for use in planning for a hospital nursing unit; filling it out is not a requirement.	Table 2.1-1 should be in the appendix as additional information to assist users of the <i>Guidelines</i> in planning a project.
85	Table 2.1-3	When this table was added to the 2010 edition, requirements for receptacles in dialysis units were inadvertently omitted.	Diagnostic and Treatment Locations Renal dialysis patient care locations 8 receptacles 4 on each side of a patient bed or lounge chair (Two receptacles on each side of the bed shall be connected to emergency power.)
95	2.2-2.3.2	The requirement for all patient rooms in an oncology nursing unit to meet PE room requirements was included in the 2010 edition in error. Current evidence does not justify making this a minimum requirement. See corrected text to the right. (Determined in November 2013 in response to an interpretation request	2.2-2.3.2 Patient Room <u>2.2-2.3.2.1</u> Patient rooms in a cancer nursing unit shall comply with the requirements of Section 2.1-2.2-2.2.2 (Patient Room). as well as <u>2.2-2.3.2.2</u> Additional requirements in Section 2.2-2.2.4.4 (Protective environment room) shall be met for patient rooms in a <u>shall be met for patient rooms in a cancer nursing unit that will be used for</u> <i>continued</i>

*All errata apply to printed copies of the 2010 FGI *Guidelines for Design and Construction of Health Care Facilities*. Errata shaded gray were corrected in the PDF on the published CD. Errata shaded yellow are new since the 10/18/16 version of the errata sheet.

PAGE	SECTION	ERROR	CORRECTION
		and originally published only in the interpretations file.)	hematopoietic cell transplantation (HCT) patients. The number of these rooms shall be determined by the services to be provided as described in the functional program and an infection control risk assessment.
104	2.2-2.6.9.1	Door opening shall be at least 4 feet (1.22 meters) wide.	Door opening shall have a minimum clear width of at least 3 feet 8 inches (1.12 meters).
131	2.2-3.1.4.2 (1)	At least one All room . . . as described in 2.1-2.4.2.2 (All room requirements), 2.1-2.4.2.4 (Special design elements); Section 2.1-8.2.2.1 (HVAC requirements for All rooms), and Part 6 (ASHRAE 170).	At least one All room . . . as described in sections 2.1-2.4.2.1 (3) (Location), 2.1-2.4.2.4 (1) (Architectural details) , 2.1-8.2.2.1 (HVAC requirements for All rooms), and Part 6 (ASHRAE 170).
188	2.5-1.4	. . . when these shared serves are when these shared <u>services</u> are . . .
189	2.5-2.2.2.6 (1)	(1) Each patient shall have access to a toilet room without having to enter a corridor.	(1) Each patient shall have access to a toilet room without having to enter a corridor. Omission of this direct access requirement shall be permitted at child or adolescent patient rooms or in specific patient rooms where the use of corridor access is part of the hospital’s written clinical risk assessment and management program.
234	3.1-8.2.4.1	Return air systems. For patient care areas, return air shall be via ducted systems.	Return air systems. See Section 6.7.1 (Air Distribution Systems—General) in Part 6: ANSI/ASHRAE/ASHE 170: Ventilation of Health Care Facilities for ducted return requirements.
275	Chapter 3.9	Specific Requirements for Gastrointestinal Endoscopy Facilities	Specific Requirements for Endoscopy Facilities
276	3.9-3.2.2.5	. . . shall be available in each procedure room.	. . . shall be available to each procedure room.
299	4.1-1.1.1	. . . The elements are required only when referenced in a specific hospital facility chapter.	. . . The elements are required only when referenced in a specific residential health care facility chapter.
338	4.3-2.2.2.8	In the reorganization, this paragraph was mistakenly labeled <i>Reserved</i> . The requirements in the 2006 edition were not meant to be altered.	4.3-2.2.2.8 Resident bathing facilities. When the functional program calls for resident bathing facilities, see 4.1-2.2.2.8 for requirements.
355	5.1-3.6.2	5.1-3.6.2 Clean Utility Room	5.1-3.6.2 Clean and Soiled Utility Rooms

Cross-Reference Corrections

PAGE	SECTION	WRONG REF	CORRECT REF
13	A1.2-1.2 a	1.2-6.4	1.2-6.2
16	A1.2-2.2.2.6	A1.5-1.2	A1.2-1.2
25	A1.2-6.1.1 c	Guidelines for noise in NICUs in Section 2.1-3.5.6.1	Guidelines for noise in NICUs in Section 2.2-2.10.9.3
89	2.2-2.1.1	Sections 2.2-2.2 through 2.2-3.8	Section 2.2

Cross-Reference Corrections, continued

PAGE	SECTION	WRONG REF	CORRECT REF
93	2.2-2.2.4.7 (2)	2.2-2.12	2.2-2.14
95	2.2-2.3.2	2.1-2.2.2	2.2-2.2.2
97	2.2-2.4.4	2.1-2.2.4.5	2.2-2.2.4.5
98	2.2-2.5.2.7	2.1-2.2.7	2.2-2.2.2.7
103	2.2-2.6.7.1	2.1-2.4.1	2.1-2.7.1
104	2.2-2.9.1.2	2.2-6	2.2-2.6
107	2.2-2.10.6.3	2.2-2.6.3	2.1-2.6.3
107	2.2-2.10.6.9	2.2-2.6.9	2.1-2.6.9
107	2.2-2.10.6.10	2.2-2.6.10	2.1-2.6.10
108	2.2-2.10.8.1	2.1-3.5.2.6	2.2-2.6.8.1
114	2.2-2.11.10.3 (4)(b)	(7)(a)	(5)(a)
114	2.2-2.11.10.3 (5)(b)	2.1-3.3.6.11 (3)	2.2-3.3.6.11 (3)
118	2.2-2.13.2.2	2.1-2.2.2.2	2.2-2.2.2.2
120	2.2-2.14.2	2.4-2.2.2	2.5-2.2.2
120	2.2-2.15.2	2.2-2.2	2.2-2.2.2
122	2.2-2.16.2.5 (1)	2.1-2.5	2.1-2.2.5
123	2.2-2.16.2.6	2.1-2.6	2.1-2.2.6
136	2.2-3.3.2.1 (1)(b)	2.1-2.11.9.2 (1)	2.2-2.11.9.2 (1)
144	2.2-3.4.4.5	2.2-3.5.4	2.2-3.5.6.2
187	2.5-1.1	2.2-2.1.4	2.2-2.14
197	2.5-4.3	2.1-4.3	2.2-4.3
224	3.1-5.3.3.3	3.7-3.6.14 (Sterilization Facilities)	3.7-5.1.2.3 (Storage for sterile supplies)
229	3.1-7.2.3.1	A1.2-2.2.1.5	A1.2-3.2.1.5
237	3.1-8.3.5.1	Section 2	3.1-3
252	3.5-3.2.2.4 (7)(a)	3.1-2.6.7	3.1-3.6.7
256	3.6-3.6.7.1	3.1-2.6.7	3.1-3.6.7
263	3.7-3.4.1.2 (3)	3.7-2.4.2.2 (2)	3.7-3.4.2.2 (2)
266	3.7-3.8.2.2	3.7-2.4.2.3 (7)	3.7-3.4.2.3 (6)
273	3.8-7.2.3.4 (2)	3.7-7.2.2.2	3.7-7.2.3.4
279	3.9-3.6.11.5	3.1-3.11 (Outpatient Facilities— Clinical Support Areas)	3.1-3.6.11.5 (Wheelchair storage space)
282	3.9-8.2.2	Table 3.1-2 (Station Outlets for Oxygen, Vacuum, and Medical Air Systems in Hospitals)	Table 3.1-1 (Station Outlets for Oxygen, Vacuum, and Medical Air in Outpatient Facilities)
282	3.9-8.4.1.1 and 8.4.1.2	Table 3.1-2	Table 3.1-1
284	3.10-3.6.7	3.1-2.6.7	3.1-3.6.7
289	3.11-3.6.1	3.1-2.1.7.1	3.1-3.6.1
306	4.1-3.1.3.2	4.1-2.1.3.1	4.2-2.2.1.3 (1)
309	4.1-7.2.2.8 (2)	2.1-8.4.3.2	4.1-8.4.3.2

Cross-Reference Corrections, continued

PAGE	SECTION	WRONG REF	CORRECT REF
311	4.1-7.2.3.1	A1.2-2.2.1.5	A1.2-3.2.1.5
325	4.2-1.1.2.2 (1)	4.2-3.1	4.2-2.2.3.1
325	4.2-1.1.2.2 (2)	4.2-3.2	4.2-2.2.3.2
328	4.2-2.2.2.8	4.2-2.2.2.8	4.1-2.2.2.8
349	4.4-8.3.2.1 (1)	Table 4.1-4	Table 4.1-3
366	5.2-2.6.13	3.1-3.1.1	3.1-3.2.2

Numbering Corrections

PAGE	CHAPTER	SECTION NUMBER THAT IS INCORRECT	CORRECTED SECTION NUMBER
48	2.1	A2.1-1.2.6.4	A2.1-2.2.6.4
115	2.2	2.2-2.11.10.3 (8) [in appendix]	A2.2-2.11.10.3 (8)
140	2.2	2.2-3.3.6.10 (3) and (4)	2.2-3.3.6.10 (2) and (3)
146	2.2	2.2-5.4.6.4	2.2-3.4.6.4
201	2.5	2.3-8.5.1, 8.5.2, 8.5.3	2.5-8.5.1, 8.5.2, 8.5.3
211	2.6	2.6-6.2.1.5 Supply storage	2.6-5.2.1.5 Supply storage
220	3.1	A2.2-3.4.2.3 (1)	A3.1-3.4.2.3 (1)
220	3.1	2.1-3.4.2.4 (2) [in appendix]	A3.1-3.4.2.4 (2)
228	3.1	2.1-7.2.1	3.1-7.2.1
262	3.7	3.7-3.3.4 Emergency Communication System	3.7-3.3.5 Emergency Communication System
262	3.7	3.7-3.3.5 Image Viewer	3.7-3.3.6 Image Viewer
262	3.7	3.7-3.3.6 Special Design Elements	3.7-3.3.7 Special Design Elements
276	3.9	3.1.1, 3.1.2, 3.1.3	3.9-3.1.1, 3.9-3.1.2, 3.9-3.1.3
330	4.2	4.1-2.2.7 through 4.1-2.2.8 (including subparagraphs)	4.2-2.2.7 through 4.2-2.2.8 (including subparagraphs)