

Checklist for Designing a Geriatric Treatment Room in the Emergency Department

January 2018

Kathryn Gallagher, MS, BSN, RN, NE-BC
Clinical Liaison, Real Estate, Design and Construction
University of Pennsylvania Health System



© 2018

The Facility Guidelines Institute
www.fgiguideelines.org
info@fgiguideelines.org

About the Facility Guidelines Institute

The Facility Guidelines Institute is a not-for-profit corporation founded in 1998 to provide leadership and continuity to the revision process for the *Guidelines for Design and Construction* documents. FGI now functions as the coordinating entity for development of the *Guidelines* series of documents using a multidisciplinary, consensus-based process and for provision of ancillary services that encourage and improve their application and use. FGI invests revenue from sales of the *Guidelines* documents to fund the activities of the next revision cycle as well as research that can inform the *Guidelines* development process.

Disclaimer

This document is provided for informational purposes only and is not and should not be construed as legal advice. The views and opinions expressed in this document are the opinions of the author and not the official position of FGI or the Health Guidelines Revision Committee.

The information provided in this document may not apply to a reader's specific situation and is not a substitute for application of the reader's own independent judgment or the advice of a competent professional. Neither FGI nor the author makes any guaranty or warranty as to the accuracy or completeness of any information contained in this document. FGI and the author disclaim liability for personal injury, property damage, or other damages of any kind, whether special, indirect, consequential, or compensatory, that may result directly or indirectly from use of or reliance on this document.

Information and recommendations in Beyond Fundamental publications and tools are not intended to be used as minimum requirements, nor are they intended to be adopted as code and enforced by an authority having jurisdiction. Rather, these publications are intended to provide supplemental information for individuals or organizations that choose to exceed the minimum (or, fundamental) design requirements in the FGI *Guidelines* documents to meet client and/or community needs.

Checklist for Designing a Geriatric Treatment Room in the Emergency Department

The geriatric population is defined as adults who are 65 years of age and older. More than 40 million Americans fall into this category according to the 2010 U.S. Census, and the percentage of adults who are 85 and older is growing at three times the rate of the general population. In the emergency department (ED), geriatric patients account for 43 percent of hospital admissions. These older adults typically present with greater challenges for care, resulting in a 20 percent longer length of stay in the emergency department than the population at large. Geriatric patients often:

- Require 50 percent more laboratory and imaging services.
- Have multiple medical co-morbidities.
- Are taking multiple medications.
- Exhibit complex physiological changes.
- Require social services for discharge planning.

These facts make it clear that emergency departments have an important role in delivering care to geriatric patients. Accordingly, health care organizations across the country are striving to develop new ED models that are better suited to this patient population.

EDs that provide geriatric-appropriate design accommodations improve the standard of care for this patient population. As well, health care organizations benefit from implementing geriatric

design accommodations because doing so helps them better allocate resources and improves admission and readmission rates. Further, geriatric-friendly design decreases iatrogenic complications and the resulting increased length of stay and decreased reimbursement.

The physical design of an ED treatment room for geriatric patients should focus on the physical environment and equipment required for their specific needs. The design should consider modifications that promote safety, comfort, mobility, memory cues, and visual and auditory perception. Although a defined space within an ED or a separate ED for geriatric patients may be beneficial, most hospitals and freestanding emergency facilities could effectively implement a program in which any ED treatment room can be made geriatric-friendly.

The checklist below was created to provide a quick reference resource, with rationale for each recommendation, for designing emergency department treatment rooms that meet the specialized needs of older adults. It can also be used to conduct a quick evaluation of patient care locations in an existing emergency department or facility. For more information on designing geriatric-friendly care accommodations, see the resources cited at the end of this document.

Designing a Geriatric Treatment Room

CHECKLIST

Physical Element or Condition	Features and Characteristics	Rationale
Treatment Room		
Space considerations	<input type="checkbox"/> Exam or reclining chair with sturdy armrests <input type="checkbox"/> Geri chair that converts to a gurney <input type="checkbox"/> Bed or gurney that lowers to seating height <input type="checkbox"/> Clearance for turning wheelchair or other equipment	<ul style="list-style-type: none"> ▶ Increases comfort for vertical patients (chair) ▶ Facilitates transfer process ▶ Decreases: <ul style="list-style-type: none"> —Fall risk during patient maneuvering —Severity of a fall
	<input type="checkbox"/> Comfortable seating for visitors <input type="checkbox"/> Secure place to store personal belongings <input type="checkbox"/> Commode at bedside <input type="checkbox"/> Monitoring equipment <input type="checkbox"/> Patient lift	<ul style="list-style-type: none"> ▶ Provides space for: <ul style="list-style-type: none"> —Wheelchair/walker-dependent patients needing transfer assistance —Temporary placement of patient-specific equipment ▶ Reduces obstacles and tripping hazards
	<input type="checkbox"/>	<ul style="list-style-type: none"> ▶ Provides comfort for caregiver or family member who may also be geriatric
	<input type="checkbox"/>	<ul style="list-style-type: none"> ▶ Protects property and relieves anxiety
	<input type="checkbox"/>	<ul style="list-style-type: none"> ▶ Provides immediate toileting option ▶ Minimizes fall risk
	<input type="checkbox"/>	<ul style="list-style-type: none"> ▶ Allows monitoring of patient status
	<input type="checkbox"/>	<ul style="list-style-type: none"> ▶ Improves staff and patient safety
	<input type="checkbox"/> Privacy curtain in multiple-patient bays <input type="checkbox"/> Private treatment rooms <input type="checkbox"/> Blinds, shade, frosting, or curtain in treatment room door to shield patient from hallway traffic	<ul style="list-style-type: none"> ▶ Facilitates communication between patient and staff ▶ Decreases likelihood patients will: <ul style="list-style-type: none"> —Withhold portions of their medical history —Refuse part of physical exam

Physical Element or Condition	Features and Characteristics	Rationale
Treatment Room, continued		
Patient control of environment	<input type="checkbox"/> Adjustable thermostat	<ul style="list-style-type: none"> ▶ Increases comfort and sense of control for patients who: <ul style="list-style-type: none"> —Have reduced thermal response —Are more sensitive to temperature fluctuation
	<input type="checkbox"/> Access to warming blankets	<ul style="list-style-type: none"> ▶ Increases patient's: <ul style="list-style-type: none"> —Visual acuity —Day/night awareness —Comfort —Sense of control
	<input type="checkbox"/> Dimmable lighting	<ul style="list-style-type: none"> ▶ Decreases patient's: <ul style="list-style-type: none"> —Sensitivity to glare —Sleep disturbances
	<input type="checkbox"/> TV remote with large buttons that are easy to operate	<ul style="list-style-type: none"> ▶ Increases ease of use by older adults with decreased visual acuity and manual dexterity
	<input type="checkbox"/> Nurse call device with large, easy-to-operate buttons	<ul style="list-style-type: none"> ▶ Increases ease of use by older adults with decreased visual acuity and manual dexterity
	<input type="checkbox"/> Ability to listen to music and choose programming without disturbing others	<ul style="list-style-type: none"> ▶ Decreases patient's: <ul style="list-style-type: none"> —Anxiety —Heart rate —Blood pressure
Toileting		
Toilet room	<input type="checkbox"/> Private or shared toilet room, conveniently located and accessible from the corridor	<ul style="list-style-type: none"> ▶ Increases patient's: <ul style="list-style-type: none"> —Comfort —Functional independence
	<input type="checkbox"/> Walker/wheelchair-accessible toilet facilities	<ul style="list-style-type: none"> ▶ Provides maneuverability for wheelchair- or walker-dependent patient
	<input type="checkbox"/> Clearance for second person to assist	<ul style="list-style-type: none"> ▶ Allows family or staff member to assist patient ▶ Reduces falls
	<input type="checkbox"/> High toilets, at least 18 inches	<ul style="list-style-type: none"> ▶ Increases patient safety
	<input type="checkbox"/> Grab bars	<ul style="list-style-type: none"> ▶ Minimizes fall risk
	<input type="checkbox"/> Non-slip/non-glare floors	
	<input type="checkbox"/> Auto-flush toilets	<ul style="list-style-type: none"> ▶ Increases ease of use
	<input type="checkbox"/> Levered door handle instead of knob	<ul style="list-style-type: none"> ▶ Accommodates those with decreased manual dexterity
	<input type="checkbox"/> Paper towel and toilet paper dispensers that don't require pulling hard to get paper	

Physical Element or Condition	Features and Characteristics	Rationale
Storage Provisions		
Mobility devices	<input type="checkbox"/> Wheelchairs, walkers, and other walking aids and devices	<ul style="list-style-type: none"> ▶ Accommodates the multitude of medical and ambulation assistive equipment often needed by geriatric patients
Other equipment and supplies	<input type="checkbox"/> Body-warming devices/warm blankets	<ul style="list-style-type: none"> ▶ Provides ready support for patient needs
	<input type="checkbox"/> Fluid warmer	
	<input type="checkbox"/> Non-slip mats/socks	
	<input type="checkbox"/> Bedside commodes	
	<input type="checkbox"/> Elevated toilet seat	
	<input type="checkbox"/> Hearing aids, hearing aid batteries, hearing amplifiers (pocket talkers), earplugs, and/or headphones	
	<input type="checkbox"/> Vision aids such as magnifier or glasses to magnify	
	<input type="checkbox"/> Monitoring equipment	
	<input type="checkbox"/> Respiratory equipment, including a fiber-optic intubation device	
Architectural Details		
Corridors	<input type="checkbox"/> Non-glare lighting focused on wayfinding cues	<ul style="list-style-type: none"> ▶ Decreases: <ul style="list-style-type: none"> —Patient and visitor confusion —Rate of falls and near falls
	<input type="checkbox"/> High-contrast large font signage	<ul style="list-style-type: none"> ▶ Decreases anxiety ▶ Improves: <ul style="list-style-type: none"> —Readability —Wayfinding
	<input type="checkbox"/> Doors in colors that contrast with walls	<ul style="list-style-type: none"> ▶ Assists wayfinding
	<input type="checkbox"/> Exit doors and out-of-bounds areas camouflaged by using the same color on doors and walls	<ul style="list-style-type: none"> ▶ Reduces: <ul style="list-style-type: none"> —Unwanted use —Wandering
Doors	<input type="checkbox"/> Doors fitted with lever handles rather than round knobs	<ul style="list-style-type: none"> ▶ Increases ease of use ▶ Accommodates those with decreased manual dexterity

Physical Element or Condition	Features and Characteristics	Rationale
Architectural Details, continued		
Handrails	<input type="checkbox"/> Handrails in colors that contrast with the floor and the wall	<ul style="list-style-type: none"> ▶ Helps older adults with visual impairment locate the handrails
	<input type="checkbox"/> Non-abrasive finish on walls behind handrails	<ul style="list-style-type: none"> ▶ Prevents abrasion injuries to knuckles
Noise control	<input type="checkbox"/> Private treatment room <input type="checkbox"/> Acoustically enhanced drapes for multiple-patient bays <input type="checkbox"/> Sound-absorbing materials for flooring, ceiling tiles, walls, curtains <input type="checkbox"/> Quiet equipment: <ul style="list-style-type: none"> ■ Wheeled equipment ■ Paper towel dispensers <input type="checkbox"/> Alarm management <input type="checkbox"/> Overhead paging systems with volume controls <input type="checkbox"/> Earplugs or headphones	<ul style="list-style-type: none"> ▶ Reduces patient: <ul style="list-style-type: none"> —Anxiety —Confusion ▶ Improves communication with caregivers ▶ Supports seniors' decreased ability to hear high-frequency ranges and increased sensitivity to loud sounds ▶ Reduces environmental noise
Surfaces		
Flooring and wall bases	<input type="checkbox"/> Non-skid floor surfaces	<ul style="list-style-type: none"> ▶ Reduces fall risk
	<input type="checkbox"/> Matte or non-glossy no wax finish floors	<ul style="list-style-type: none"> ▶ Eliminates glare ▶ Reduces falls
Walls	<input type="checkbox"/> Contrasting colors for baseboard and wall	<ul style="list-style-type: none"> ▶ Defines floor edge visually to assist in ambulation
Color and pattern	<input type="checkbox"/> Use of colors at the warm end of the spectrum (oranges, yellows, and reds)	<ul style="list-style-type: none"> ▶ Responds to seniors' decreased ability to differentiate cool colors (blues, greens, and purples)
	<input type="checkbox"/> Avoidance of bold patterns with dominant contrasts or flecking patterns	<ul style="list-style-type: none"> ▶ Reduces: <ul style="list-style-type: none"> —Excess visual stimulation or appearance of vibration, which can exacerbate confusion and cause vertigo —Misperception of patterns as obstacles or objects to avoid while walking

Physical Element or Condition	Features and Characteristics	Rationale
Furnishings		
Furniture	<input type="checkbox"/> Exam/reclining chairs with sturdy armrests <input type="checkbox"/> Gurney with an extra-thick or pressure-redistributing foam mattress <input type="checkbox"/> Gurney or bed that lowers to enable patients to easily stand for safe transferring <input type="checkbox"/> Soft, moisture-proof, easily cleanable upholstery with no surface joints or seams	<ul style="list-style-type: none"> ▶ Increases patient comfort ▶ Reduces pain ▶ Facilitates transfers <ul style="list-style-type: none"> ▶ Lowers risk of skin breakdown ▶ Reduces pain <ul style="list-style-type: none"> ▶ Reduces fall risk <ul style="list-style-type: none"> ▶ Protects fragile skin ▶ Reduces surface contamination linked to health care-associated infections
Accessory	<input type="checkbox"/> High-contrast large clocks	<ul style="list-style-type: none"> ▶ Improves readability
Electrical Systems		
Lighting	<input type="checkbox"/> Night-lights in bathrooms and doorways with motion sensors <input type="checkbox"/> Soft light (170-watt incandescent with ultra-high diffusion coating) or exposure to natural light <input type="checkbox"/> Even and well-diffused lights such as type T5 or type T8 <input type="checkbox"/> Simultaneous use of multiple light sources, combining direct lighting (e.g., ceiling-mounted fluorescents) with indirect lighting (e.g., high-pressure, floor-standing up-lights or covered lamps with a diffuse reflector shining down)	<ul style="list-style-type: none"> ▶ Facilitates wayfinding ▶ Minimizes fall risk <ul style="list-style-type: none"> ▶ Improves recovery times <ul style="list-style-type: none"> ▶ Reduces glare <ul style="list-style-type: none"> ▶ Increases lighting for older adults, who require three to four times more light than the general population for visual clarity
Support for communication devices	<input type="checkbox"/> Convenience outlet to charge cell phones <input type="checkbox"/> Extra cell phone charging cords	<ul style="list-style-type: none"> ▶ Facilitates staff and patient communication

Resources

American College of Emergency Physicians, American Geriatrics Society, Emergency Nurses Association, and Society for Academic Emergency Medicine. *The Geriatric Emergency Department Guidelines* (2013).

Parke, Belinda, and Kathleen Friesen. *Code Plus Physical Design Components for an Elder Friendly Hospital*, 2nd ed, (Fraser Health, 2015).

Senior Friendly Hospitals, Regional Geriatric Program of Toronto. "Senior Friendly Hospital Toolkit," accessed January 25, 2018, <http://seniorfriendlyhospitals.ca/toolkit>.

ABOUT THE AUTHOR

Kathryn Gallagher, MS, RN, BSN, NE-BC, is a clinical liaison with the Department of Real Estate, Design and Construction at the University of Pennsylvania Health System. As a member of the team currently designing a new hospital pavilion for Penn Medicine, she serves as the voice of the patient and the clinical and non-clinical staff. She facilitates engagement with staff, patients, and the community for Penn Medicine design projects from the beginning of the design process through occupancy with the goal of creating facilities that provide not only excellent clinical care but the highest quality of safety and satisfaction for patients and staff. Ms. Gallagher began her nursing career with the University of Pennsylvania Health System as a clinical nurse in a variety of critical care units and subsequently worked in nursing administration for several years. She holds a Master of Science in Strategic and Organizational Leadership and is a member of the Nursing Institute for Healthcare Design and the American Organization of Nurse Executives. Ms. Gallagher was a member of the FGI 2018 Health Guidelines Revision Committee.